

---

**Date:** Fri, 27 Oct 2006 23:11:54 -0500 [10/27/2006 11:11:54 PM CDT]

---

**From:** txfsca <txfsca@earthlink.net>

---

**To:** undisclosed recipient <fusiblelink@earthlink.net>

---

**Subject:** Pump Recall Information

---

This information is provided by Steve Randall, NFSA Southwest Regional Manager.

NEWS from CPSC

U.S. Consumer Product Safety Commission  
Office of Information and Public Affairs  
Washington, DC 20207

FOR IMMEDIATE RELEASE  
October 25, 2006  
Release #07-018

Firm's Recall Hotline: (800) 984-9199  
CPSC Recall Hotline: (800) 638-2772  
CPSC Media Contact: (301) 504-7908

ITT Water Technology Inc. Expands Recall of Faulty Pumps  
for Fire Suppression Systems

WASHINGTON, D.C. - The U.S. Consumer Product Safety  
Commission, in Cooperation with the firm named below, today announced a  
voluntary Recall of the following consumer product.

Name of Product: Goulds Pumps, Bell & Gossett and Red  
Jacket Water Products Brand Pumps for Fire Suppression Systems

Units: About 3,000 additional units (18,300 units  
recalled in August 2006)

Manufacturer: ITT Water Technology Inc., of Auburn, N.Y.

Hazard: A mechanical part on these pumps was not fully  
secured, which Can lead to the pump failing during use. If pumps sold  
with fire Suppression systems fail, the risk of fire damage  
increases. The pump Itself does not pose a fire hazard. These pumps were  
previously recalled For the same hazard in August 2006. The recall has now  
been expanded to Include additional date codes and the dates sold have  
been expanded.

Incidents/Injuries: ITT Water Technology Inc. Has  
received one report of A pump failing to start during a system test. No  
injuries have been Reported.

Description: The recalled pumps are general in purpose,  
but are Sometimes used in fire suppression systems. The pumps  
were sold under The Goulds Pumps, Bell & Gossett and Red Jacket Water  
Products brands. The pumps can be identified by having Model NPE, NPO,  
MCC, MCS, SM or Series 3530 on their nameplate. Recalled pumps were  
manufactured between December 2005 and September 7, 2006. They have date code  
M05, A06, B06, C06, D06, E06, F06, G06, H06 or J06. The date code is  
the first three Digits of the serial number on the pump nameplate.

Sold at: Pump distributors nationwide from December 2005  
through September 2006 for about \$800.

Manufactured in: United States

Remedy: Installers of fire suppression systems will be contacted by ITT Water Technology Inc. To schedule an inspection and replacement. Please Contact ITT Water Technology Inc. If you have not been contacted yet.

Consumer Contact: For more information, call ITT Water Technology Inc. At (800) 984-9199 between 8 a.m. And 5 p.m. ET Monday through Friday, or Visit one of the company's Web sites at [www.goulds.com](http://www.goulds.com), [www.bellgossett.com](http://www.bellgossett.com) or [www.redjacketwaterproducts.com](http://www.redjacketwaterproducts.com)

To see this recall on CPSC's web site, including pictures of the Recalled products, please go to:  
<http://www.cpsc.gov/cpsc/pub/prerel/prhtml07/07018.html>

Sincerely,

Alan P. McCartney, CSP, CHCM, EMT-P  
Senior Technical Specialist - Property

Loss Prevention - Liberty Mutual Agency Markets  
62 Maple Avenue  
Keene, New Hampshire 03431  
(603) 358-4560  
(603) 357-9595 (fax)  
[alan.mccartney@libertymutual.com](mailto:alan.mccartney@libertymutual.com)

---